



# Hydroscience *INC.*

PO Box 4978 Toms River, NJ 08754 ■ P: 732.349.9692 ■ F: 732.349.9729 ■ Hydroscienceinc.com ■ Lic: 13VH00981900

July 17, 2015

Home Sweet Home  
3333 Hwy Route 9 N  
Freehold, NJ 07728

**RE: Results - Lead paint investigation at 321 W. Farms Road, Howell, NJ**

Dear Ms. Camporeale:

On July 13, 2015, Hydroscience, Inc. conducted a lead paint investigation at the above referenced property.

In order to perform the lead paint investigation a Hydroscience Inc. technician utilized 3M™ LeadCheck™ Swabs to determine the presence of lead. These swabs are recognized by the EPA when used by a certified renovator.

The Hydroscience, Inc. technician tested four (4) interior walls. In each of the four (4) sample locations, no evidence of lead was detected in the paint. Please note that the EPA has evaluated and recognized these swabs demonstrate probability (with 95% confidence) of false positive response less than or equal to 10% of the time for paint containing lead below the regulated level, 1.0 mg/cm<sup>2</sup>.

Due to the negative results demonstrated by the LeadCheck™ Swabs, Hydroscience, Inc. did not need to collect any paint chip samples.

Hydroscience, Inc. is pleased to have the opportunity to serve your environment needs. Should you have any questions or need additional environmental services, please do not hesitate to call our office.

For the firm;  
Hydroscience Inc.

Robert Salt  
Cert ID: R-I-18846-15-0007