

EXTRACT FAN LOCATED ABOVE COOKING AREA AND DUCTED TO THE OUTSIDE KITCHEN AREA TO BE MECHANICALLY VENTED WITH MIN 20 AIR CHANGES PER HOUR SEATING AREA TO BE MECHANICALLY VENTED WITH MIN 12 AIR CHANGES PER HOUR

STAFF TOILET VENTED BY EXISTING EXTRACT FAN MIN 15 LTS PER SECOND

## SOUTH AYRSHIRE COUNCIL

Approved under the Town and Country Planning (Scotland) Act, 1997 (As Amended), in accordance with the plans submitted and subject to any conditions that may be specified in the notification of this decision by South Ayrshire.