



ALL OFFICE SPACE HAS BEEN
 SPRINKLED AS PER NFPA 13
 ORDINARY HAZARD PIPE
 SCHEDULING

1339
 1342
 1482

MEAD Loss Control Consultants
 Approved _____
 Not Approved _____
 Subject to Comments Dated 6/27/88
 By *Richard B. ...*

TYPE	SIZE	DEG.	NO.
Chrome	Pand.	1/2	165
			58
TOTAL SPRKS. THIS SHEET			56
TOTAL SPRKS. THIS JOB			

FIRETRON INC.
 207 C. Williams Blvd.
 1901 Village Box #1863
 Lenoir, N.C. 28645

DANA CORP. BRISTOL VIRGINIA
OFFICES A & B

SCALE: _____ DATE: 6/28/88 DRAWN BY: RBT/TS JOB NO: 88006 DWG. NO: 7 of 8