

FLAG NOTES:

- 1 PROVIDE NEW PASSIVE INFRARED WALL SWITCH DIMMER OCCUPANCY SENSOR, LEVITON IPVD6 OR WATT STOPPER PW-101D. TEST AND ENSURE DIMMING COMPATIBILITY WITH LED DOWNLIGHTS IN ROOM.
- 2 PROVIDE NEW PASSIVE INFRARED WALL SWITCH OCCUPANCY SENSOR, WATT STOPPER PW-101, OR EQUAL.
- 3 RECONNECT TO EXISTING LIGHTING CIRCUIT INDICATED.

GENERAL NOTES:

- 1. REPLACE ALL EXISTING LIGHT FIXTURES WITH NEW LED DOWN LIGHT LUMINAIRES.
- 2. 5/8" LED DOWNLIGHTS ALL AREAS EXCEPT FOR BATHROOMS WHICH USE A 4" DOWNLIGHT.
- 3. REPLACE EXISTING RESTROOM 2 x 2, 2-LAMP, 32 WATT U-6 T8 WITH NEW LED 4" DOWN LIGHTS.
- 4. ALL SWITCHES INDICATED WITH A "D" SHALL BE A DIMMER SWITCH WITH OCCUPANCY SENSOR.
- 5. ALL SWITCHES SHALL BE AN INTEGRAL SWITCH/OCCUPANCY SENSOR, UNLESS OTHERWISE NOTED.

JR CLARK
ENTERPRISES
1109 W Littleton Blvd. Littleton, CO 80120
303-748-3735
BIM Modeling | Design | Construction
Engineering | Landscaping & Irrigation
Services for Commercial & Residential

Littleton
ANYTHING BUT LITTLE

ackerman
engineering, inc

JR CLARK ENTERPRISES
HEADQUARTERS
1109 W. LITTLETON BLVD
LITTLETON, CO 80120

Sheet Name:
LEVEL 2 -
LIGHTING PLAN

Sheet Number:
E202



1 LEVEL 2 - ELECTRICAL LIGHTING
1/2" = 1'-0"