



Rick Harper <rharper@eragrizzard.com>

Utility Inquiry G16-052 & G16-062

1 message

Bethany Bryant <bbryant@wildwood-fl.gov>

Tue, Jul 14, 2026 at 3:14 PM

To: "rharper@eragrizzard.com" <rharper@eragrizzard.com>

Cc: Angelica Colon <acolon@wildwood-fl.gov>, Kristen Findley <kfindley@wildwood-fl.gov>

Good afternoon,

Please see response below regarding the referenced parcel.



Bethany Bryant

Development Services Dept.

City of Wildwood

100 N Main Street

Wildwood FL 34785

Ph: 352-330-1334

www.wildwood-fl.gov


Good morning,

Water: 12-inch water main (blue line) located along the north side of CR 44 and the eastern boundary line of parcel G16-073

Sewer: 8-inch Force main (green line) located along the south side of CR 44

***Please note that exact locations will need to be verified by the developer/property owner. The maps are not always 100% correct on the side of the road the line is on. They will need to call in locates to 811 and then have a survey done to get exact locations. Additionally, depending on what type of development is being proposed, line size and capacity will need to be determined . ***

Kind regards,



\