

Energy performance certificate (EPC) recommendation report

49 South Street
ROMFORD
RM1 1NL

Report number
2011-4605-5060-8605-4991

Valid until
14 May 2036

Energy rating and EPC

This property's energy rating is B.

For more information on the property's energy performance, see the EPC for this property.

Recommendations

Changes that may pay for themselves within 3 years

Recommendation	Potential impact on carbon emissions
In some spaces, the solar gain limit defined in the NCM is exceeded, which might cause overheating. Consider solar control measures such as the application of reflective coating or shading devices to windows.	Medium

Changes that may pay for themselves within 3 to 7 years

Recommendation	Potential impact on carbon emissions
Add time control to heating system.	Medium
Add optimum start/stop to the heating system.	Medium

Changes that may pay for themselves in over 7 years

Recommendation	Potential impact on carbon emissions
Some windows have high U-values - consider installing secondary glazing.	Medium
Add local temperature control to the heating system.	Medium
Add weather compensation controls to heating system.	Medium
Add local time control to heating system.	Medium
Some solid walls are poorly insulated - introduce or improve internal wall insulation.	Medium

Property and report details

Report issued on	15 May 2026
Total useful floor area	84 square metres
Building environment	Heating and Natural Ventilation
Calculation tool	G-ISBEM Ltd, G-ISBEM, v25.3, SBEM, v6.1.e.0

Assessor's details

Assessor's name	Usman Hussain
Telephone	07939302868
Email	usman@energyexpertise.co.uk
Employer's name	High Street EPC
Employer's address	07951022907
Assessor ID	QUID201051
Assessor's declaration	The assessor is not related to the owner of the property.
Accreditation scheme	Quidos Limited
