

# The Washington Post

1301 K Street NW Washington DC 20005

## GenSLer

ARCHITECT  
2020 K Street, Northwest, Suite 200,  
Washington, DC 20006  
202.721.5200

### Smislova, Kehnemui & Associates, P.A.

STRUCTURAL ENGINEER  
12505 Park Potomac Avenue, Suite 200, Potomac, MD 20854  
301.881.1441


### WSP Group

MEP ENGINEER  
1627 K Street NW, Suite 1006, Washington, DC, 20006  
202.296.1924

### SBLD Studio

LIGHTING CONSULTANT  
132 West 36th Street, New York, NY, 10018  
212.391.4230

## KEY PLAN



Δ	Date	Description
A	04/15/15	ISSUE FOR PERMIT
1	06/12/15	ISSUE FOR CONSTRUCTION

Seal / Signature

## SHEET NOTES

## GENERAL NOTES

- INDEPENDENTLY SUPPORT HVAC UNIT LOCAL DISCONNECT FROM THE STRUCTURE ADJACENT TO THE MECHANICAL UNIT. COORDINATE LOCATION AND ORIENTATION WITH DUCTWORK TO ALLOW FOR MINIMUM 3'-0" CLEAR IN FRONT OF THE DISCONNECT.
- VAV UNITS ON FLOORS 6, 7 WEST AND 8 WEST WITH ELECTRICAL HEAT CONNECTED TO PANEL GLPH-7 SHALL BE CONTROLLED SUCH THAT WHILE BEING POWERED FROM THE TENANT GENERATOR THE ELECTRICAL HEAT IS DISABLED VIA THE BUILDING'S BMS SYSTEM.

Project Name

The Washington Post

Project Number

09.7487.000

Scale

1/8" = 1'-0"

Description

ELECTRICAL HVAC LEVEL 09

# E0209M