

# The Washington Post

1301 K Street NW Washington DC 20005

## Gensler

ARCHITECT  
2020 K Street, Northwest, Suite 200,  
Washington, DC 20006  
202.721.5000

## Smislova, Kehnemui & Associates, P.A.

STRUCTURAL ENGINEER  
12505 Park Potomac Avenue, Suite 200, Potomac, MD 20854  
301.881.1441


## WSP Group

MEP ENGINEER  
1627 K Street NW, Suite 1006, Washington, DC, 20006  
202.295.1904

## SBLD Studio

LIGHTING CONSULTANT  
132 West 36th Street, New York, NY, 10018  
212.391.4230

### KEY PLAN



Date	Description
04/15/15	ISSUE FOR PERMIT
06/12/15	ISSUE FOR CONSTRUCTION

Seal / Signature

### SHEET NOTES

- 480227V PANEL H4A1 PROVIDED IN THE BASE BUILDING DEMOLITION PACKAGE TO SERVE THE AUDITORIUM VAV BOXES. PROVIDE BRANCH CIRCUITING INDICATED. REFER TO SHEET E0205M.

### GENERAL NOTES

- INDEPENDENTLY SUPPORT HVAC UNIT LOCAL DISCONNECT FROM THE STRUCTURE ADJACENT TO THE MECHANICAL UNIT. COORDINATE LOCATION AND ORIENTATION WITH DUCTWORK TO ALLOW FOR MINIMUM 3'-0" CLEAR IN FRONT OF THE DISCONNECT.
- VAV UNITS ON FLOORS 6, 7 WEST AND 8 WEST WITH ELECTRICAL HEAT CONNECTED TO PANEL GLPH-7 SHALL BE CONTROLLED SUCH THAT WHILE BEING POWERED FROM THE TENANT GENERATOR THE ELECTRICAL HEAT IS DISABLED VIA THE BUILDING'S BMS SYSTEM.

### Project Name

The Washington Post

### Project Number

09.7487.000

### Scale

1/8" = 1'-0"

### Description

ELECTRICAL HVAC LEVEL 04

# E0204M