


BUILDING #	BUILDING DESCRIPTION	AVERAGE DAILY SEWER DESIGN FLOW (BASED ON NODD REQUIREMENTS)
1A	WOODWORKING SHOP WITH 1 BEDROOM OFFICE APARTMENT & EMPLOYEES	447 @ 250 GPD + 4 EMPLOYEES @ 28 GPD/A = 440 GPD
2A	4 UNIT APARTMENT WITH 1 BA + 2 BEDROOM UNITS PLUS 1 BA + 3 BEDROOM UNIT	3 UNITS @ 240 GPD/A + 1 UNIT @ 350 GPD/A = 1060 GPD
2B	4 UNIT APARTMENT WITH 1 BA + 2 BEDROOM UNITS PLUS 1 BA + 3 BEDROOM UNIT	3 UNITS @ 240 GPD/A + 1 UNIT @ 350 GPD/A = 1060 GPD
2C	4 UNIT APARTMENT WITH 1 BA + 2 BEDROOM UNITS PLUS 1 BA + 3 BEDROOM UNIT	3 UNITS @ 240 GPD/A + 1 UNIT @ 350 GPD/A = 1060 GPD
	TOTAL FLOW	3640 GPD

BUILDING #	BUILDING DESCRIPTION	AVERAGE DAILY SEWER DESIGN FLOW (BASED ON NODD REQUIREMENTS)
1A	WOODWORKING SHOP WITH 1 BEDROOM OFFICE APARTMENT & EMPLOYEES	447 @ 250 GPD + 4 EMPLOYEES @ 28 GPD/A = 440 GPD
2A	4 UNIT APARTMENT WITH 1 BA + 2 BEDROOM UNITS PLUS 1 BA + 3 BEDROOM UNIT	3 UNITS @ 240 GPD/A + 1 UNIT @ 350 GPD/A = 1060 GPD
2B	4 UNIT APARTMENT WITH 1 BA + 2 BEDROOM UNITS PLUS 1 BA + 3 BEDROOM UNIT	3 UNITS @ 240 GPD/A + 1 UNIT @ 350 GPD/A = 1060 GPD
2C	4 UNIT APARTMENT WITH 1 BA + 2 BEDROOM UNITS PLUS 1 BA + 3 BEDROOM UNIT	3 UNITS @ 240 GPD/A + 1 UNIT @ 350 GPD/A = 1060 GPD
	TOTAL FLOW	3640 GPD


ESTIMATED FUTURE WATER & SEWER CONNECTIONS			3500 GPD
			PHASE 1 AVERAGE DAILY SEWER DESIGN FLOW =
BUILDING #	BUILDING DESCRIPTION	AVERAGE DAILY SEWER DESIGN FLOW (BASED ON NCCO4 REQUIREMENTS)	
19	INDUSTRIAL WAREHOUSE TYPE OFFICE (ESTIMATED TO INCLUDE 1 BEDROOM APT, 3 LOADING BAYS AND 4 ELEVATORS)	660 GPD	
20 THROUGH 21	EACH 4 UNIT APARTMENT BUILDINGS WITH EACH HAVING 3 BA, 2 BEDROOM, DINING'S PLUS 1 BA, 3 BEDROOM UNIT	6400 GPD	
TOTAL ESTIMATED FUTURE AVERAGE DAILY SEWER DESIGN FLOW =		7120 GPD	

[illegible]

PRELIMINARY - DO NOT USE FOR
CONSTRUCTION

PRELIMINARY WATER AND SANITARY SEWER EXTENSION PLAN

**PROPOSED WATER AND SANITARY
MAIN EXTENSIONS TO
MACH 2 PROPERTY**



CAUTION:
EXISTING WATER, SEWER,
STORM AND OTHER UTILITIES
PROPOSED IN THE FOUNDATION
NEW CONCRETE SHALL BE
EXISTING UTILITIES AND
THE PROPOSED.