


PLAN VIEW OF ACTIVITY BUILDING-LEVEL 1
SCALE 1/8" = 1'-0"

NO.	DATE	BY	REVISIONS - SEE FLAGGED AREA ON PLAN
1	11-1-95	JG	AS BUILT



CONTRACT NAME	HUMAN SUPPORT SERVICES OF HOUSTON	SCALE	1/8" = 1'-0"
CONTRACT NO.	9009 BOONE ROAD	DRAWN BY	P. OWEN
	HOUSTON, TEXAS 77099	CHECKED BY	
CONTRACT TITLE	SAME AS ABOVE	DATE	8-14-95
DESCRIPTION	ALARM AND DETECTION OF ACTIVITY BUILDING-LEVEL 1	THESE PLANS PREPARED AT	HOUSTON, TEXAS
OWNER		ENGINEERING DEPARTMENT	
ENGINEER		SHEET NO.	2 OF 3
CITY		CONTRACT NO.	52.308503-1R2
INSURANCE			



IMPORTANT
This drawing and the information and design application herein contained is the property of Grinnell Fire Protection Systems Company, Inc. and for the subsurface and is loaned upon the express condition that the same be returned to GFPS upon request; all information herein contained shall be treated as secret and confidential; no reproduction of this drawing or any part thereof shall be made without the written consent of GFPS.

CONTRACT RESPONSIBILITIES		COORDINATION RECORD	
ITEM	G. F. P. S. OTHERS	CONTR. NAME	REF. DWG. REV./DATE
110V POWER TO FACP	N/A		
CONDUIT AND STANDARD BOXES	YES		
WIRE TO HVAC SHUTDOWNS	N/A		
WIRE TO ELEVATOR CONTROLS	N/A		
WIRE TO SECURITY SYSTEM	N/A		
WIRE TO MONITORING PANEL	N/A		
WIRE TO TELEPHONE BOARD	N/A		

SYMBOL LEGEND				SYMBOL LEGEND				SYMBOL LEGEND						
SYMBOL	QTY	DESCRIPTION	MANUFACTURER	PART NUMBER	SYMBOL	QTY	DESCRIPTION	MANUFACTURER	PART NUMBER	SYMBOL	QTY	DESCRIPTION	MANUFACTURER	PART NUMBER
FA	1	FIRE ALARM CONTROL PANEL	EDWARDS	CM1	W	23	HORN/STROBE UNIT	WHEELLOCK	HT-24-LN-1FR	W	2	WATERFLOW SWITCH		EXISTING/NEW
F	10	MANUAL PULL STATION	EDWARDS	270-SPC	WB	3	WEATHERPROOF BACK BOX	WHEELLOCK	WBB	V	2	TAMPER SWITCH		EXISTING/NEW
1	46	IONIZATION SMOKE DETECTOR	EDWARDS	1551	R	2	STROBE UNIT	WHEELLOCK	LS1M-24-1FR					
135	3	HEAT DETECTOR	EDWARDS	280B	RM	1	EOL RELAY 24VDC	NOTIFIER	77-716-2					
4	3	HEAT DETECTOR	EDWARDS	5551	CM	2	ISOLATION MODULE	EST	MS00XF					
					MM	14	MONITOR MODULE	EST	MS01NF					

PROVIDED BY SPRINKLER CONTRACT
GRINNELL FIRE PROTECTION SYSTEM CO.
8600 HOWARD DRIVE
HOUSTON, TEXAS 77017
ACR-76243-187A
KARL T. WARRICK *Karl Warrick*
APS-0491 DATE 8/15/95