



Space Profile for

Unit: #L09B

Area: 2368 sq ft

Address


842 Northwest Loop 410

San Antonio, TX 78216



400 N. Tampa St., Suite 2210

Tampa, FL, 33602



Legend

	Breaker Panel		Fire Extinguisher		Ceiling Fan w/ Light		Fire Sprinkler
	Circular Column		Fire Alarm Pulldown		Rectangular Column		Pocket Door
	Appliance Outlet		Glass Door		Refrigerator		Track Lighting
	Fire Alarm		Handicap Handrail		Roll-Up Door		2-Bulb Fluorescent Lighting
	Drinking Fountain		Roof Hatch		Sink		3-Bulb Fluorescent Lighting
	Door		HVAC Unit		Swing Door		4-Bulb Fluorescent Lighting
	Double Hung Door		Recessed Light		Toilet		Ceiling Air Vent
	Electrical Outlet		Staircase		Can Light		Air Diffuser
	Emergency Light		Water Heater		Urinal		Ceiling Fan w/o Light
	Exit Light		Telephone Panel		Thermostat		Air Handler
	Tankless Water Heater		Window Wall Opening		RJ 45		Fire Alarm Control Panel
	Step Down Transformer		Maintenance Sink		Window		
	Disconnect						

Disclaimer: All items may not show on feature pages.

Space Overview

Overview	Actual Square Footage	Measured Depth of Space	Total Depth of Space	Has Stepdown Transformer
	2368 SQFT	85' 0"	85' 0"	No

Thickness	Front Wall	Rear Wall	Left Wall	Right Wall
	0' 5"	0' 5"	0' 8"	0' 8"

Flooring	Concrete	Carpet	Tile	Other	Unit	Total
	1869.43 SQFT		320.1 SQFT			2368 SQFT

Ceiling Information	Height From Floor To Ceiling	Height From Floor To Bottom Of Deck	Height From Floor To Bottom Of Joist
	Front: 17' 9" Back: 17' 9"	Front: 19' 2" Back: 19' 2"	Front: 17' 9" Back: 17' 9"

Ceiling Information Cont.	Clear Ceiling Height	Height From Floor To Bottom Of Girder	Number Of Acoustical Tiles
	9' 0"		

Other Cont.	Phone Board Location	Mop Sink Location	Thermostat Location	Dmarc Distance	Are Interior Walls Full Height
					No

Other Cont.	Hazardous Materials	Loading Dock	Are Demising Walls Full Height	Changes In Demising Wall Thickness
	No	No	No	No

Mechanical

HVAC	Reference	Manufacturer	Model	Serial	Tonnage	Year	Notes
	7	RHEEM	RLNL-A048CK 000	7526F051206201	4	2012	
	8	RHEEM	RLMB-A120CL 000	6553F080902005	10	2009	

Electric

Disconnect	Reference	Amps	Location	Panel Number	Manufacturer	Notes	Handle or Breaker
	12	200	Left Exterior	Not Listed	Square D		Handle

Service Panel	Reference	Amps	Service Type	Panel Type	Panel UL Number	Manufacturer	Location	Notes
	1	0	120/208	QO Panelboard	Not Listed	Square D	Electrical Room	

Electric Meter	Reference	Meter #	Location	Meter Reading	Read On	Voltage	Notes
	12	6 144 937	Left Exterior	79242	Thu Mar 3 2022	120-480	

Plumbing

Water Heater	Reference	Manufacturer	Model	Serial	Gallons	Tankless	Water Line (in)	Location	Notes
	1	Inaccessible	Inaccessible	Inaccessible		0	No	.75	Above Electrical Room

Backflows	Number of Backflows	Location	Size	Notes
	2	Bar Area and Left Exterior of Building		Inaccessible

House Water Meter	Reference	Meter #	Location	Size	Notes
	3		0418369	Left Exterior	

Waste

No assets available for this section.

Fire

Sprinkler Heads	Sprinkler Heads Present	Sprinkler Head Type	Riser Located in Space	Riser Location	Additional Information
	20	Upright / pendent	No	Left side of building	


Gas

No assets available for this section.

Room

Restroom	Unit	Description
	Restroom 2	Women's restroom
	Restroom 1	Men's Restroom

Reflective Ceiling Plan 1



Storefront 1

