

WAKE

WAKE COUNTY HEALTH DEPARTMENT SEPTIC TANK LAYOUT AND PERMIT

37928

TAX MAP NO. 427

PARCEL NO. 2816

Requit

PERMIT NO. B

OPERATION PERMIT ☐

cedar Fork

CONTRACTOR

Permit is Cert of Completion from

OWNER

W. H. C.

DAVIS

The Willie Davis Home

DATE

11/7/87

LOCATION

SP 1635

down Driv. Dr.

1st green house on R. pt

SUBDIVISION NAME

LOT NO.

SECTION OR BLOCK NO.

REPAIR ☒ ORIGINAL PERMIT NO. NONE

GARBAGE DISPOSAL UNIT YES ☐ NO ☒

HOUSE ☒ MOBILE HOME ☐ BUSINESS ☐

NO. BEDROOMS 2

LOT AREA 30,000

SIZE OF TANK

750 / Est 900 gal.

NITRIFICATION LINE

Est 600 / Add 300 sq. ft.

DEPTH OF STONE IN LINES: 12"

EST TOTAL 155

RISER AND BAFFLE REQUIRED ☒

PUMP REQUIRED ☐

WATER SUPPLY: INDIVIDUAL ☒ PUBLIC ☐ OTHER ☐

* PERMIT VOID 36 MONTHS FROM DATE OF ISSUANCE.

* PERMIT VOID IF NOT IN COMPLIANCE WITH ZONING REGULATIONS.

* PERMIT MAY BE VOIDED IF SITE ALTERATIONS MADE

LAYOUT BY

Gene Bristow

3/26/87

DATE

Otto Lyons

INSTALLED BY

Gene Bristow

APPROVED BY

