


Y X.3 X W.7 W U.5 U T S R PO.9 O.10 N.5 N M L K



The Washington Post

1301 K Street NW Washington DC 20005

Gensler

ARCHITECT
2020 K Street, Northwest, Suite 200,
Washington, DC 20006
202.773.1500


Structural Engineer
Smsilova, Kehnemui & Associates, P.A.
12505 Park Potomac Avenue, Suite 200, Potomac, MD 20854
301.881.1441

MEP ENGINEER
WSP Group
1627 K Street NW, Suite 1006, Washington, DC, 20006
202.296.1904

Lighting Consultant
SBLD Studio
132 West 36th Street, New York, NY, 10018
212.391.4230

3

KEY PLAN



Date	Description
04/15/15	ISSUE FOR PERMIT
06/12/15	ISSUE FOR CONSTRUCTION

5

6

7

Seal / Signature

7B

8

SHEET NOTES

1 IN-ROW COOLING UNITS PROVIDED WITH HARD-WIRED CONNECTION AND INTEGRAL DISCONNECT SWITCH. TYPICAL OF (14).

GENERAL NOTES

- A. INDEPENDENTLY SUPPORT HVAC UNIT LOCAL DISCONNECT FROM THE STRUCTURE ADJACENT TO THE MECHANICAL UNIT. COORDINATE LOCATION AND ORIENTATION WITH DUCTWORK TO ALLOW FOR MINIMUM 3'-0" CLEAR IN FRONT OF THE DISCONNECT.
- B. VAV UNITS ON FLOORS 6, 7 WEST AND 8 WEST WITH ELECTRICAL HEAT CONNECTED TO PANEL GLPH-7 SHALL BE CONTROLLED SUCH THAT WHILE BEING POWERED FROM THE TENANT GENERATOR THE ELECTRICAL HEAT IS DISABLED VIA THE BUILDING'S BMS SYSTEM.

Project Name
The Washington Post

Project Number
09.7487.000

Scale
1/8" = 1'-0"

Description
ELECTRICAL HVAC LEVEL 06

E0206M