

Soil Evaluation Report

Owner: Adams Inspirational Church Applicant: Rev Eugene Padgett Sanitarian: Shirley

Date: 3/13/01

1st: 6 Map: 6 Blk: 23 Par: 82

Subdivision: _____ Lot: _____

Section: _____

at: _____ Long: _____ EDE: _____ Test Type: Mound Conv. Trench Shallow Trench Other



Hole Name
Soil Profile

Buffer 5

Type of Test:

New Repair

Start

1st inch

2nd inch

3rd inch

4th inch

hole dia./conv factor

rate/result

depth/penetration

Hole Name	WT	SA-2 ^{+1 from SA-1}	change in elev	SA-3	change in elev	change in elev
Soil Profile	0-8'-light, blocky clay loam 8-17'-SCL orange w/gravel 17'-dry Contractor unable to dig any deeper	0-4'-tan clay loam 4'-13'-dark orange SCL no gravel		0-3'-tan clay loam 3-9'-dark orange SCL 9-10'-dark orange SCL w/gravel		goal is to obtain an easement to accomodate a church containing 600 seats $\frac{1900}{x2}$ = 950 gallons per day
1st inch		1.45		3.25		- 12 bedroom Hse
2nd inch		1.46		3.28		only one side was
3rd inch		1.50		3.40		part of
4th inch		1.55		3.53		- there are also plans for a school to be built & daycare center none of the info was given prior to last date
hole dia./conv factor		8"	x 2	16" casing	1	
rate/result		10mp	sat.	3mp	sat.	
depth/penetration		13'	2p	12'	2p	

Comments: test locations were chosen by Contractor & church representative - Thomas Kent
accurate knowledge of property lines is not available. Also unavailable
the exact intentions of the church

Soil Evaluation Report

Owner: Adams Inspirational Church Applicant: Rev Eugene Radcliffe Sanitarian: S. Adams Date: 3/13/01
 Dist: 6th Map: 6 Blk: 23 Par: 85 Subdivision: _____ Lot: _____ Section: _____
 Lat: _____ Long: _____ EDE: _____ Test Type: Mound Conv. Trench Shallow Trench Other

Hole Name

Soil Profile

Buff: 5

Type of Test:

New

Repair

Start

1st inch

2nd inch

3rd inch

4th inch

hole dia./conv factor

rate/result

depth/penetration

Comments: Mr Simms Contractor informed to fill in all test holes before leaving test site on 3/13/01

J:\sewer\soils\01.xls

SA 4 WT	change in elev	change in elev	change in elev
0-4' - light tan C.L.			
5-9' - orange S.L.L. w/gravel			
7-10' - dark orange S.L. coarse			
10'-15' - dry & caving orange S.L.			
4.23			
4.26			
4.31			
4.37			
8"	2		
12mp	Sat.		
10'	10		

Charles County PGM GIS Interactive Map




7/22/2026, 10:47:23 AM

 Tax Parcel Data - Charles County


 SixInchImagery2023_2024

World_Hillshade



Maryland State Department of Assessments and Taxation, Maryland
Department of Planning, and Charles County Maryland Department of

Charles County PGM GIS Interactive Map




7/27/2026, 1:56:19 PM

Streams - Polylines

Tax Parcel Data - Charles County

World_Hillshade



Charles County Maryland, Maryland State Department of Assessments and Taxation, Maryland Department of Planning, and Charles County Maryland